



Sanitary Sewer Overflow Report

12/26/2009

10:18 AM

Overflow Start: 12/25/2009 9:00 AM
Overflow End: 12/25/2009 5:00 PM

Location: 329 FREYER DR
Manhole in street in front of property

Primary Cause: Blockage
Secondary Cause: Unknown
Estimated Volume: 9,600 Gallons
Waterway Affected: Sope Creek

Description Of Incident: An unknown partial blockage caused a manhole to backup and overflow into a nearby storm drain.

Description Of Response: Marietta water personnel cleared the blockage by hydro jet and normal service was restored. The surrounding sewer mains will be cleaned and CCTV'd to examine for defects as well.

Contact: Tim Marshall
Environmental Compliance Coordinator
Phone: 770-794-5229
Fax: 770-794-2286
email: tmarshall@mariettaga.gov