



Sanitary Sewer Overflow Report

10/13/2009

8:39 AM

Overflow Start:	10/12/2009	11:00 AM
Overflow End:	10/12/2009	1:30 PM

Location:	627 N MARIETTA PKWY
	In Water Dept. Yard

Primary Cause:	Capacity Failure
Secondary Cause:	Wet Weather I/I
Estimated Volume:	3,450 Gallons
Waterway Affected:	Sope Creek

Description Of Incident:	Heavy sustained rainfall caused localized flooding and infiltration of sewer mains across much of the Marietta Water service area. Parts of our sewer system capacity were overcome causing manholes to overflow until floodwaters receded somewhat. Impact minimal.
--------------------------	--

Description Of Response:	We are using these data for planning future improvements to our system.
--------------------------	---

Contact:	Tim Marshall Environmental Compliance Coordinator Phone: 770-794-5229 Fax: 770-794-2286 email: tmarshall@mariettaga.gov
----------	---