



---

## Sanitary Sewer Overflow Report

10/13/2009

8:41 AM

---

Overflow Start: 10/12/2009 11:00 AM  
Overflow End: 10/12/2009 1:30 PM

---

Location: 800 OLD MERRITT RD  
On road to city dump

---

Primary Cause: Capacity Failure  
Secondary Cause: Wet Weather I/I  
Estimated Volume: 2,550 Gallons  
Waterway Affected: Sope Creek

---

Description Of Incident: Heavy sustained rainfall caused localized flooding and infiltration of sewer mains across much of the Marietta Water service area. Parts of our sewer system capacity were overcome causing manholes to overflow until floodwaters receded somewhat. Impact minimal.

Description Of Response: We are using these data for planning future improvements to our system.

---

Contact: Tim Marshall  
Environmental Compliance Coordinator  
Phone: 770-794-5229  
Fax: 770-794-2286  
email: [tmarshall@mariettaga.gov](mailto:tmarshall@mariettaga.gov)