



---

## Sanitary Sewer Overflow Report

10/29/2009

3:52 PM

---

Overflow Start: 10/28/2009 5:00 PM  
Overflow End: 10/28/2009 6:30 PM

---

Location: 2492 PRINCESS LN  
Cleanout in front of residence

---

Primary Cause: Blockage  
Secondary Cause: Unknown  
Estimated Volume: 1,350 Gallons  
Waterway Affected: Rottenwood Creek

---

Description Of Incident: An unknown blockage caused a section of sewer main servicing about 7-8 houses to backup and relieve from the service clean out at the above address.

Description Of Response: Marietta Water personnel quickly relieved the blockage thus restoring normal service. Surrounding lines will be cleaned to avoid future issues. Manholes in street need to be uncovered from recent paving as well.

---

Contact: Tim Marshall  
Environmental Compliance Coordinator  
Phone: 770-794-5229  
Fax: 770-794-2286  
email: tmarshall@mariettaga.gov