



Sanitary Sewer Overflow Report

11/16/2009

8:04 AM

Overflow Start: 11/15/2009 9:00 AM
Overflow End: 11/15/2009 9:14 AM

Location: 29 WHITLOCK SQ
At creek between residences

Primary Cause: Manhole Failure
Secondary Cause: Other
Estimated Volume: 6,600 Gallons
Waterway Affected: Ward Creek

Description Of Incident: An unknown abandoned sewer line was leaking very slightly into nearby creek.

Description Of Response: Marietta Water cleaned the live sewer main and blocked off the abandoned line thus stopping the leakage. A manhole defect found during investigation is also being repaired.

Contact: Tim Marshall
Environmental Compliance Coordinator
Phone: 770-794-5229
Fax: 770-794-2286
email: tmarshall@mariettaga.gov