



Lewis Park Site Improvements

Addendum # 3

November 13, 2013

Questions:

1. 8" HDPE storm pipe comes in single wall or double wall. I'd assume the City would want the double wall pipe (N-12) which is "smooth" inside. The single wall interior would have the corrugations and traps sediment more readily. *Please use double walled pipe.*

The bid opening date will not change.

END OF ADDENDUM #3